



## NOTE:

1. BOTTOM OF INLET PIPE INTO MANHOLE MUST BE AT LEAST 3-INCHES ABOVE THE BOTTOM OF THE TROUGH AND EXTENDED 3-INCHES BEYOND THE INSIDE OF THE MANHOLE WALL.
2. WIDTH AND DIAMETER OF TROUGH MUST BE SAME AS DIAMETER OF INLET PIPE.
3. SANITARY WASTE LINE MUST CONNECT AT LEAST TWO FEET DOWNSTREAM OF SAMPLING MANHOLE.
4. MANHOLE OPENING SHALL BE CENTERED OVER INLET PIPE.
5. THE SAMPLING MANHOLE SHALL BE INSTALLED LEVEL AND ON A COMPACTED FOUNDATION WITH 12" BEDDING MATERIAL AS SPECIFIED IN 407.01

NO SCALE



**JORDAN BASIN**  
IMPROVEMENT DISTRICT

## SAMPLING MANHOLE DETAIL

DRAWN:	DESIGNED:	CHECKED:	APPROVED:
DATE	FILE NAME	DRAWING NAME	
AUG 2024		PT-4	