



NOTES:

1. INVERT D1 SHALL MATCH THE 0.75 DEPTH POINT OF D2, UNLESS OTHERWISE APPROVED BY DISTRICT ENGINEER.
2. AFTER ALL GRADING AROUND MANHOLE HAS BEEN COMPLETED AND FINAL SURFACING IS IN PLACE, REMOVE DEBRIS AND TEMPORARY PLUGS OR PLYWOOD FROM INSIDE OF MANHOLES.
3. STUBS FOR FUTURE CONNECTIONS SHALL BE PLUGGED UNTIL ACTIVATION FOR SERVICE IS APPROVED BY SVSD.

DOGHOUSE OPENING SHALL BE PERFORMED BY MANUFACTURER OR SAW CUT TO FIT PIPE OUTSIDE DIAMETER PLUS 6 INCHES.

NO SCALE



JORDAN BASIN
IMPROVEMENT DISTRICT

**MANHOLE ON EXISTING
PIPE DETAIL**

DRAWN:	DESIGNED:	CHECKED:	APPROVED:
DATE AUG 2024	FILE NAME	DRAWING NAME SS-2B	